



FOR THE SCOPE OF
ACCREDITATION UNDER NVLAP LAB
CODE 100402-0.

REPORT

3933 US ROUTE 11, CORTLAND, NEW YORK 13045

Project No. G102182053

Date: July 23, 2015

REPORT NO. 102182053CRT-017

TEST OF ONE RECESSED DOWNLIGHTS

MODEL NO. A2VOCLED1-0730K-FL
LED MODEL NO. CREE CXB 1507
DRIVER MODEL NO. HATCH LC-14

RENDERED TO:

LEXINGTON LIGHTING GROUP, LLC DBA VANTAGE LIGHTING
645 MYLES STANDISH BLVD
TAUNTON, MA 02780

TESTS: Electrical and Photometric tests as required to the IESNA test standard.

STATEMENT OF LIMITATION: This report must not be used by the client to claim product certification, approval, or endorsement by NVLAP, NIST, or any agency of the federal government.

AUTHORIZATION The testing performed was authorized by signed quote number .

STANDARDS USED:

IESNA LM-79 - 2008: Electrical and Photometric Measurements of Solid State Lighting

DESCRIPTION OF SAMPLE: The client submitted one prototype sample of model number A2VOCLED1-0730K-FL. The sample was received by Intertek on June 24, 2015 in undamaged condition and one sample was tested as received. The sample designation was CRT1507081017-001-004.

DATE OF TESTS: July 22, 2015

This report is for the exclusive use of Intertek's Client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this report. Only the Client is authorized to copy or distribute this report and then only in its entirety. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test results in this report are relevant only to the sample tested. This report by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.



SUMMARY:

MODEL NO. A2VOCLED1-0730K-FL
DESCRIPTION: RECESSED DOWNLIGHTS

Criteria	Results
Light Output (Lumens)	970
Total Power (W)	11.52
Lumen Efficacy (Lm/W)	84.2
Power Factor ()	0.977

EQUIPMENT LIST

Equipment Used	Model No.	Control No.	Last Cal.	Cal. Due
LSI High Speed Mirror Goniometer	6440	---	7/10/2015	8/10/2015
Elgar AC Power Supply	CW1251	---	VBU	VBU
Sorenson DC Power Supply	XG 150-10	---	VBU	VBU
Yokogawa Power Analyzer	WT210	E464	4/20/2015	4/20/2016
ExTech Hygro Thermometer	445703	T1357	12/10/2014	12/10/2015
Fisher Scientific Stopwatch	14-649-9	N1405	8/25/2014	8/25/2015
M-D Building Products Digital Level	Smart Tool	L112	3/25/2015	3/25/2016
NIST Luminous Intensity Standard Source	NBS10322	N1427	12/12/2014	12/12/2015
NIST Luminous Intensity Standard Source	NBS10215	N1432	12/12/2014	12/12/2015
NIST Luminous Intensity Standard Source	H754	N1433	12/12/2014	12/12/2015
NIST Luminous Flux Standard Source	NBS10428	N1424	12/17/2014	12/17/2015

TEST METHODS:

Seasoning in Sample Orientation – LED Products

No seasoning was performed in accordance with IESNA LM-79.

Photometric and Electrical measurements – Distribution Method

A LSI Type C High Speed Model 6440 Mirror Goniometer was used to measure the intensity (candelas) at each angle of distribution for the SSL sample.

Ambient temperature was measured equal to the height of the sample mounted on the goniometer equipment. The SSL sample was operated on the client provided driver at rated input volts in its designated orientation. The SSL sample was allowed to stabilize for at least thirty minutes before measurements were made. Stabilization procedures to LM-79 were followed. Electrical measurements including voltage, current, and power were measured using a power analyzer.


RESULTS:

Photometric and Electrical Measurements at Ambient Temperature (25°C +/- 1°C) – Distribution Method

Intertek Control No.	Base Orientation	Input Voltage (VAC)	Input Current (mA)	Input Power (W)	Input Power Factor ()	Light Output (Lumens)	Lumen Efficacy (lm/W)
CRT1507081017-001-002	Base Up	120.0	98.3	11.52	0.977	969.7	84.21

Intensity (Candlepower) Summary at 25°C - Candelas

Angle	0	22.5	45	67.5	90
0	536	536	536	536	536
5	524	526	527	529	528
10	500	504	509	510	507
15	478	482	486	489	483
20	456	459	463	463	457
25	434	435	437	437	432
30	411	412	412	412	408
35	386	388	388	388	385
40	363	364	342	361	360
45	289	286	192	265	282
50	126	124	95	116	124
55	79	76	75	79	80
60	63	63	64	64	65
65	50	50	50	52	52
70	36	35	35	38	40
75	22	22	22	25	26
80	10	10	11	14	15
85	3	2	2	4	6
90	0	0	0	0	0




RESULTS:


Illumination Plots

Mounting Height: 10

Illuminance - Cone of Light



Isoillumination Plot




Zonal Lumen Summary and Percentages at 25°C

Zone	Lumens	% Luminaire
0-30	386.9	39.9
0-40	629.0	64.9
0-60	890.4	91.8
60-90	79.3	8.2
0-90	969.7	100.0
90-180	0.0	0.0
0-180	969.7	100.0

Zonal Lumens and Percentages at 25°C

Zone	Lumens	% Luminaire
0-10	49.6	5.1
10-20	136.4	14.1
20-30	200.9	20.7
30-40	242.1	25.0
40-50	188.7	19.5
50-60	72.7	7.5
60-70	49.9	5.1
70-80	24.8	2.6
80-90	4.6	0.5

PRODUCT PICTURE:



CONCLUSION

The results tabulated in this report are representative of the actual test samples submitted for this report only. The data is provided to the client for further evaluation. Compliance to the referenced specification requirements was not determined in this report.

In Charge Of Tests:



Gerald Gray
Associate Engineer
Lighting Division

Report Reviewed By:



Jeffrey Davis
Engineering Supervisor
Lighting Division

Attachments: IES File - CRT1507081017-001-003